## **Panasonic**

# Operating Instructions Air Conditioner



4-Way Cassette (Type U3)

Model No.

INDOOR UNIT

4-Way Cassette (Type U3)

S-3650PU3E S-6071PU3E S-1014PU3E

**OUTDOOR UNIT** 

Single Split
See the page 12.



#### **ENGLISH**

Before operating the unit, read these operating instructions thoroughly and keep them for future reference.

Thank you for purchasing this Panasonic product. This product is a commercial air conditioner indoor unit. Installation Instructions attached.

## Contents

Safety Precautions	
Precautions for Use	5
Names of Parts	
Maintenance	
Operation Mechanism	7
• nanoe™ X Function	8
Troubleshooting	10
Before Requesting Services	
Specifications	13
• Indoor unit	
Outdoor unit	

	WARNING	This symbol shows that this equipment uses a flammable refrigerant. If the refrigerant is leaked, together with an external ignition source, there is a possibility of ignition.
PLAMMABLE AS 2	CAUTION	This symbol shows type of flammable refrigerant contained in the system.
	CAUTION	This symbol shows that a service personnel should be handling this equipment with reference to the Technical Manual.
i	CAUTION	This symbol shows that there is information included in the Operating Instructions and/or Installation Instructions.

#### **Product Information**

If you have problems or questions concerning your Air Conditioner, you will need the following information. Model and serial numbers are on the nameplate.

Model No. Serial No. Date of purchase Dealer's address Phone number

#### Important Information Regarding The Refrigerant Used

**NOTE** 

Refer to the Installation Instructions attached to the outdoor unit.

## Safety Precautions

The following symbols used in this manual, alert you to potentially dangerous conditions to users, service personnel or the appliance:




This symbol refers to a hazard or WARNING unsafe practice which can result in severe personal injury or death.



This symbol refers to a hazard or unsafe practice which can result in personal injury or product or property damage.





- Read these Operating Instructions carefully before using this air conditioner. If you still have any difficulties or problems, consult your dealer for help.
- This air conditioner is designed to give you comfortable room conditions. Use this only for its intended purpose as described in these Operating Instructions.

### **!\WARNING**



Confirm to authorized dealer or specialist on usage of specified refrigerant type. Using of refrigerant other than the specified type may cause product damage, burst and injury etc.

This air conditioner has no ventilator for intaking fresh air from outdoors. You must open doors or windows frequently when you use gas or oil heating appliances in the same room, which consume a lot of oxygen from the air.

Otherwise there is a risk of suffocation in an extreme case.



Never use or store gasoline or other flammable vapor or liquid near the air conditioner — it is very dangerous.

Do not use this appliance in a potentially explosive atmosphere.

Never touch the unit with wet hands.

Do not insert your fingers or other objects into the air conditioner indoor or outdoor unit, rotating parts may cause injury.

### **! WARNING**



If the refrigerant comes in contact with a flame, it produces a toxic gas.

For safety, be sure to turn the air conditioner off and also to disconnect the power before cleaning or servicing.

Pull off the power plug from a receptacle, or switch off the breaker, or switch off the power disconnecting mean to isolate the air conditioner from the main power supply in case of emergency.

Dispose of according to national and/or local legislation.



This product must not be modified or disassembled under any circumstances.

Modified or disassembled unit may cause fire, electric shock or injury.

Do not clean inside the indoor and outdoor units by users. Engage authorized dealer or specialist for cleaning.

In case of malfunction of this appliance, do not repair by yourself. Contact the sales dealer or service dealer for a repair and disposal.



Provide a power outlet to be used exclusively for each unit, and a power supply disconnect, Earth Leakage Circuit Breaker (ELCB) or Residual Current Device (RCD) for overcurrent protection should be provided in the exclusive line.

Provide a power outlet exclusively for each unit, and full disconnection means having a contact separation in all poles must be incorporated in the fixed wiring in accordance with the wiring rules.

To prevent possible hazards from insulation failure, the unit must be grounded.





Do not use modified cord, joint cord, extension cord or unspecified cord to prevent overheating and fire.



The appliance shall be stored in a room without continuously operating ignition sources (for example: open flames, an operating gas appliance or an operating electric heater).

Be aware that refrigerants may not contain an odour.

An unventilated area where the appliance using flammable refrigerants is installed shall be so constructed that should any refrigerant leak, it will not stagnate so as to create a fire or explosion hazard.

The appliance shall be stored in a well-ventilated area where the room size corresponds to the room area as specified for operation.

After the unit is installed, never fail to ask the installer for the floor space of the room where the unit is installed and the refrigerant charge amount.

In case the unit or the room divider is changed, never fail to consult the sales dealer or service dealer.



Do not use means to accelerate the defrosting process or to clean, other than those recommended by the manufacturer.

Do not pierce or burn.

In cases that require mechanical ventilation, ventilation openings shall be kept clear of obstruction.

### **! WARNING**



The appliance shall be stored in a room without continuously operating open flames (for example: an operating gas appliance) and ignition sources (for example: an operating electric heater).



Stop using the product when any abnormality/failure occurs and disconnect the power plug or turn off the power switch and breaker. (Risk of smoke/fire/electric shock) Examples of abnormality/failure:

The ELCB trips frequently.

- •The product sometimes does not start when turned on.
- The power is sometimes disconnected when the cord is moved.
- Burnt odor or abnormal noise is detected during operation.
- The body is deformed or abnormally hot.
- Water leaks from the indoor unit.
- Power cord or plug becomes abnormally hot.
- Fan speed cannot be controlled.
- The unit stops running immediately even if it is switched on for operation.
- The fan does not stop even if the operation is stopped.

Contact immediately your local dealer for maintenance/repair.



Do not sit or step on the unit. You may fall down accidentally.



### **!** CAUTION



This appliance is intended to be used by expert or trained users in shops, in light industry and on farms, or for commercial use by lay persons.

This appliance is not intended for use by persons (including children) with reduced physical, sensory or mental capabilities, or lack of experience and knowledge, unless they have been given supervision or instruction concerning use of the appliance by a person responsible for their safety. Children should be supervised to ensure that they do not play with the appliance.

<for European market only>
This appliance can be used by children aged from 8 years and above and persons with reduced physical, sensory or mental capabilities or lack of experience and knowledge if they have been given supervision or instruction concerning use of the appliance in a safe way and understand the hazards involved. Children shall not play with the appliance. Cleaning and user maintenance shall not be made by children without supervision.

Keep the fire alarm and the air outlet at least 1.5 m away from the unit.

Do not cool or heat the room too much if babies or invalids are present.



Do not turn the air conditioner on and off from the power mains switch. Use the ON/OFF operation button.

Do not stick anything into the air outlet of the outdoor unit. This is dangerous because the fan is rotating at high speed.



Do not touch the air inlet or the sharp aluminum fins of the outdoor unit. You may get injured.



Do not stick any object into the FAN CASE. You may be injured and the unit may be damaged.





#### **NOTICE**

- The appliance shall be stored so as to prevent mechanical damage from occurring.
- The compressor may occasionally stop during thunderstorms. This is not a mechanical failure. The unit automatically recovers after a few minutes.
- The English text is the original instructions. Other languages are translation of the original instructions.

## **Precautions for Use**

#### Installation

- This air conditioner must be installed properly by qualified installation technicians in accordance with the Installation Instructions provided with the unit.
- Before installation, check that the voltage of the electric supply in your home or office is the same as the voltage shown on the nameplate.

### **!** WARNING

#### Avoid the following locations for installation.

- Locations where smoke or combustible gas exists.
   Also locations of extremely high temperature such as a greenhouse.
- Locations where excessively high heat-generating objects are placed.

#### Attention:

 Avoid installing the outdoor unit where salty sea water can splash directly onto it or in sulphurous air near a spa. (To protect the air conditioner from heavy corrosion)

### Wiring

- All wiring must conform to the local electrical codes.
   (Consult your dealer or a qualified electrician for details.)
- Each unit must be properly grounded with a ground (or earth) wire or through the supply wiring.
- Wiring must be done by a qualified electrician.

### **Operation Preparation**

## Turn the power mains on 5 hours before the start of operation.

(For warm-up)

Leave the power mains ON for continuous use.



#### **NOTE**

Pull off the power plug from a receptacle, or switch off the breaker, or switch off the power disconnecting mean to isolate the air conditioner from the main power supply when not in use for a long time.

### Tips for Energy Saving

#### Avoid

- Do not block the air intake and outlet of the unit. (If either is obstructed, the unit will not function well, causing malfunction.)
- During cooling operation, use sunshades, blinds or curtains to prevent direct sunlight from entering the room.

#### Do

- Always keep the air filter clean.
   (A clogged filter will impair the performance of the unit.)
   "Maintenance" (P.7)
- To prevent conditioned air from escaping, keep windows, doors and any other openings closed.

### Information for Users on Collection and Disposal of Old Equipment and Used Batteries



These symbols on the products, packaging, and/or accompanying documents mean that used electrical and electronic products and batteries should not be mixed with general household waste.

For proper treatment, recovery and recycling of old products and used batteries, please take them to applicable collection points, in accordance with your national legislation and the Directives 2002/96/EC and 2006/66/EC. By disposing of these products and batteries correctly, you will help to save valuable resources and prevent any potential negative effects on human health and the environment which could otherwise arise from inappropriate waste handling.

For more information about collection and recycling of old products and batteries, please contact your local municipality, your waste disposal service or the point of sale where you purchased the items.

Penalties may be applicable for incorrect disposal of this waste, in accordance with national legislation.

For business users in the European Union If you wish to discard electrical and electronic equipment, please contact your dealer or supplier for further information.

### [Information on Disposal in other Countries outside the European Union]

These symbols are only valid in the European Union. If you wish to discard these items, please contact your local authorities or dealer and ask for the correct method of disposal.




### Note for the battery symbol (bottom two symbol examples):



This symbol might be used in combination with a chemical symbol. In this case it complies with the requirement set by the Directive for the chemical involved.

## Names of Parts

#### **INDOOR UNIT**



Label (attached to the lid of electrical component box)


This air conditioner incorporates a biocidal product. Ionized air generated by a device incorporated in the air conditioner deactivates bacteria and

viruses in the air, and on surfaces, and inhibits mould growth on surfaces.

Active substances: free radicals generated in situ from ambient air or water



#### **OUTDOOR UNIT**





**PZ3** (Type 60, 71)



**PZ2** (Type 60, 71)



**PZ2** (Type 100, 125, 140)




**PZH2** (Type 36, 50, 60)






**PZH2** (Type 71)



**PZH2** (Type 100, 125, 140)



**Optional** 

#### **Wireless Remote** Controller



Model No. CZ-RWS3 The receiver: Model No. CZ-RWRU3\* (Type U3) CZ-RWRC3 (For all indoor units)

#### **Timer Remote** Controller



Model No. CZ-RTC4

For all indoor units

#### **High-spec Wired Remote Controller**



Model No. CZ-RTC5B

For all indoor units

#### Wired Remote Controller



Model No. CZ-RTC6\*

For all indoor units

(Infrared Remote Controller)

Read the Operating Instructions included with the Remote Controller.

#### ■ Operation & Adjusting Airflow Direction

Refer to the Operating Instructions attached to the Remote Controller.

## **Maintenance**


### **WARNING**

- For safety, be sure to turn the air conditioner off and disconnect the power before cleaning. (Otherwise, electric shock or injury may result because the fan is rotating at high speed.)
- Do not pour water on the indoor unit. (This may damage the internal components and cause an electric shock hazard.)

### **CAUTION**

- Never use solvents or harsh chemicals. Also, do not wipe plastic parts using very hot water. (This may cause deformation or change in colour.)
- Some metal edges and fins are sharp. Be careful when you clean those parts. (Injury may result.)
- Use a firm stool or ladder when cleaning an indoor unit installed in high locations.

#### Indoor unit (e.g. Type U3)




- The internal coil and other components of the outdoor unit must be cleaned periodically.
  - Consult your dealer or service center.

#### ■ Air Filter Maintenance

Consult your dealer or service center when the ## (Filter) appears on the display of the wired remote controller.

Timer Remote Controller



High-spec Wired Remote Controller

Filter indicator



Wired Remote Controller



### **Operation Mechanism**

#### ■ Heating performance

- This air conditioner utilizes outside air for heating; its heating performance reduces as outside temperature decreases.
  - →In the event that heating is not sufficient, please use an additional heating appliance.

#### ■ Defrosting

- This appliance may start defrosting operation to melt frost formed in the outdoor unit.
  - ① Defrosting starts: The indoor unit fan stops (or the speed becomes extremely slow).
    - →"\*\*)" (STANDBY) appears.
  - ② Heating operation resumes after several minutes: The indoor unit fan remains stopped (or it will run at a very slow speed) until the indoor heat exchanger coil warms up sufficiently.
    - → "\*\* (STANDBY) appears.
  - Defrosting is complete: The indoor unit fan starts operation.
    - → "\*\* " (STANDBY) disappears.

#### ■ "DRY" operation

- Once the room temperature reaches the level that was set, the outdoor unit repeats the cycle of turning on and off automatically.
- When the room temperature is more likely to reach the level that was set, the fan speed is set to "breeze" (light wind) automatically.


## ■ Should power failure occur while the unit is running

The unit will resume operation automatically. Operation settings prior to power failure will be used.

## nanoe™ X Function

### Display during operation of nanoe™ X

Example: Initial screen of remote controller



[nanoeX]: Under operation of nanoe™ X


nanoe™ X For a freshness and cleaner environment

nanoe™ X generates negative ions using the air in the room to give a healthy air.

It also reduces the smell in the room, and constrains propagations of mold and bacteria.

When purchased, the nanoe™ X function is designed to automatically operate.


• If you wish to set to OFF, refer to the operating instructions for the remote controller adaptable to nanoe™ X function.



### **Internal Cleaning Function**


#### ■ Internal Cleaning Operation

When cooling or dry operation stopped, internal drying and nanoe  $^{\text{TM}}$  X circulation airflow is activated in order to suppress the mold proliferation inside the unit (airflow passage, fan, heat exchanger). According to the installation environment or operating hours, mold proliferation or inhibition of mold growth will be changed.



- Operating conditions and operating hours
   Operates in cooling or dry mode for more than 5 minutes.
   When finished, the internal cleaning operation is started.
   Drives for about Max 75 minutes.
- The figure at right shows the display during the internal cleaning operation.
- If you wish to resume operating during internal cleaning, press ().
- To stop the internal cleaning operation Press .

When the internal cleaning operation finished and stopped, the remote control display shows at right.



[山] START

#### NOTES:

- Internal cleaning function is not possible to use any remote controller other than that of nanoe™ X function.
- Internal cleaning function is not designed to automatically operate even if the remote controller which is adaptable to the nanoe™ X function is connected when purchased. If you wish to set to ON, refer to the operating instructions for the remote controller which is adaptable to the nanoe™ X function.
- In case that the operation time of the air conditioner is less than 5 minutes, the internal cleaning operation cannot be performed.
- While the internal cleaning operation is running, the indoor temperature may occasionally increase.

# **Troubleshooting**

Check before consulting or requesting services.

		Symptom		Cause / Action				
	Noise	Sound like streaming water is heard during operation or after operation.		Sound of refrigerant liquid flowing inside unit     Sound of drainage water through drain pipe				
	NOISE	Cracking noise is heard during operation or when operation stops.		Sound due to temperature changes of parts				
	Discharg	ed air smells during operation.	<b>&gt;</b>	Indoor odor components, cigarette odor and cosmetic odor accumulated in the air conditioner and its air is discharged.     The unit inside is dirty. (Contact your dealer.)				
		s accumulate near the air outlet poling operation.	<b>&gt;</b>	Internal moisture is cooled by cool wind and accumulates as dewdrops.				
	Fog occu	og occurs during cooling operation.		og occurs during cooling operation.		og occurs during cooling operation.		If the air conditioner has been installed at places such as restaurants where large amounts of oil mist exist, cleaning is necessary because the unit inside (heat exchanger) is dirty. (Contact your dealer.)
	Fog occu	irs during heating operation.		Defrost operation is in process.				
Indoor unit	The fan is rotating for a while even though operation stops.		<b>&gt;</b>	Fan rotation makes operation smooth.     The fan may rotate to dry the heat exchanger depending on the setting.				
lnd	Airflow direction	Airflow direction changes while operating. Airflow direction cannot be set. Airflow direction cannot be changed.		When air discharge temperature is low during heating operation, or during defrost operation, horizontal wind flow is made automatically.     The flap position may be set individually. (Type U3)				
	Dust is discharged.		<b>&gt;</b>	Dust accumulated inside the indoor unit is discharged.				
		tial high-speed operation, the fan es rotates faster than the setting ninutes)	<b>&gt;</b>	This is for operation check in order to confirm whether the fan motor rotation is within the range of use.				
	Humming	g noise comes out.	<b>&gt;</b>	• This is the sound of nanoe™ X being discharged.				
	nanoeX controlle	noeX is not displayed on the remote itroller.		• Has nanoe™ X been set to OFF?  → Set to ON.				
	<u> </u>	$\overline{\mathbf{X}}$ is displayed on the remote r.		• nanoe™ X is considered abnormal. (Contact your dealer.)				
it		e power is turned on immediately / eration is stopped and resumed		Operation is not activated for the first approx. 3 minutes because the compressor protection circuit is activated.				
Outdoor unit	Noise oc	curs during heating operation.		Defrost operation is in process.				
Outdo	Steam comes out during heating operation.		<b>&gt;</b>	- Deliost operation is in process.				
		continues to rotate even after the n is stopped using the remote r.		This is for smooth operation.				

### **Before Requesting Services**

Symptom	Cause	Action		
The air	Power failure or after power failure	Press the power ON/OFF button on the remote controller.		
conditioner does not operate although the	The operation (power) button is turned off.	If the breaker is turned off, turn the power on.     If the breaker has been tripped, consult your dealer without turning it on.		
power is turned on.	Fuse blow out.	Contact your dealer.		
	The air intake or air outlet of indoor and outdoor units is clogged with dust.	Remove the dust.		
	The fan speed switch is set to "Low".*	Change to "Medium" or "High".*		
	Improper temperature settings			
Poor cooling or heating	The room is exposed to direct sunlight in cooling mode.	See "Tips for Energy Saving". (P.5)		
performance	Doors or windows are open.			
<b>P</b>	The air filter is clogged.	See "Maintenance". (P.7)		
	Too many heat sources in the room in cooling mode.	Use minimum heat sources and in a short time.		
	Too many people in the room in cooling mode.	Lower the temperature setting or change to "Medium" or "High".*		

<sup>\*</sup> Regarding the remote control display, see the page 13.

## If your air conditioner does not work properly even after checking each item of "Before Requesting Services" and "Troubleshooting"

- Stop the operation immediately and turn the power off. Then contact your dealer and report the serial number and symptom. You also report if the inspection mark ⚠ and the letters E, F, H, L, P in combination with numbers appear on the LCD of the remote controller.
- Never repair the air conditioner by yourself since it is very dangerous for you to do so.

### Connectable outdoor unit lineup

### Europe

### ■ Refrigerant type: R32

	· -				
Outdoor u	Outdoor unit type		45	50	60
PZH2	1-phase	U-36PZH2E5	_	U-50PZH2E5	U-60PZH2E5
PZMZ	3-phase	_	_	_	_
PZ2	1-phase	_	_	_	U-60PZ2E5
PZ2	3-phase	-	-	-	-
Outdoor u	nit type	71	100	125	140
PZH2	1-phase	U-71PZH2E5	U-100PZH2E5	U-125PZH2E5	U-140PZH2E5
PZMZ	3-phase	U-71PZH2E8	U-100PZH2E8	U-125PZH2E8	U-140PZH2E8
PZ2	1-phase	U-71PZ2E5	U-100PZ2E5	U-125PZ2E5	U-140PZ2E5
PZ2	3-phase	-	U-100PZ2E8	U-125PZ2E8	U-140PZ2E8
				•	
Outdoor u	nit type	200	250		
PZH2	3-phase	U-200PZH2E8	U-250PZH2E8		
Outdoor u	nit type	36	50	60	71
PZ3	1-phase	U-36PZ3E5	U-50PZ3E5	U-60PZ3E5	U-71PZ3E5

#### Oceania

#### ■ Refrigerant type: R32

Outdoor ur	Outdoor unit type		45	50	60
PZ2	1-phase	_	_	_	U-60PZ2R5
FZZ	3-phase	_	_	_	_
Outdoor ur	Outdoor unit type		100	125	140
PZH2	1-phase	U-71PZH2R5	U-100PZH2R5	U-125PZH2R5	U-140PZH2R5
FZIIZ	3-phase	_	U-100PZH2R8	U-125PZH2R8	U-140PZH2R8
PZ2	1-phase	U-71PZ2R5	U-100PZ2R5	U-125PZ2R5	U-140PZ2R5
PZ2	3-phase	_	U-100PZ2R8	U-125PZ2R8	U-140PZ2R8

## **Specifications**

### **Indoor unit**

### 4-Way Cassette (Type U3)

Model Name		S-3650PU3E			S-6071PU3E		S-1014PU3E					
Power so	urce (Eu	rope)	220 - 230 - 240 V∼ 50 Hz									
Power so	urce (Oc	eania)		-			230	- 240 V~ 50	) Hz			
Cooling	one eltr	kW	3.6	4.5	5.0	6.0	7.1	10.0	12.5	14.0		
Cooling	араспу	BTU/h	12,300	15,400	17,100	20,500	24,200	34,100	42,700	47,800		
Sensible		kW	3.2	3.7	4.0	4.9	5.5	8.3	9.5	10.2		
	Latent	kW	0.4	0.8	1.0	1.1	1.6	1.7	3.0	3.8		
Ueeting e	oncelty	kW	4.0	5.2	5.6	7.0	8.0	11.2	14.0	16.0		
Heating o	араспу	BTU/h	13,600	17,700	19,100	23,900	27,300	38,200	47,800	54,600		
Cooling electric power input*		kW	0.024	0.026	0.029	0.038	0.042	0.100	0.110	0.120		
Heating e		kW	0.022	0.024	0.027	0.036	0.040	0.095	0.105	0.115		
Sound	High	dB(A)	30	31	32	36	37	45	46	47		
pressure	Medium	dB(A)	28	28	29	31	31	38	39	40		
level***	Low	dB(A)	27	27	27	28	28	32	33	34		
Sound	High	dB(A)	45	46	47	51	52	60	61	62		
power	Medium	dB(A)	43	43	44	46	46	53	54	55		
level***	Low	dB(A)	42	42	42	43	43	47	48	49		
Unit dimensions (H×W×D) **		289.5×950×950	289.5×950×950	289.5×950×950	289.5×950×950	289.5×950×950	352.5×950×950	352.5×950×950	352.5×950×950			
Net weigl	nt **	kg	24	24	24	25	25	30	30	30		

Operation condition temperature range
• Cooling mode : 18°C~32°C DB • Heating mode : 16°C~30°C DB

- In the case of nanoe™ X "OFF"
- \*\* Values include the dimensions and weight of an optional ceiling panel.
- \*\*\* Fan speed display on the remote controller

High : <b>\$\$</b> }}	(CZ-RTC4),	(CZ-RTC5B, CZ-RTC6*)
Medium :	(CZ-RTC4),	(CZ-RTC5B, CZ-RTC6*)
Low : <b>\$</b>	(CZ-RTC4),	(CZ-RTC5B, CZ-RTC6*)

## **Specifications**

#### **Outdoor unit**

### Single Split Outdoor Unit (R32)

F	Model Name		U-36PZH2E5	U-50PZH2E5	U-60PZH2E5
Europe	Power so	urce	220 -	230 - 240 V~ 5	50 Hz
Cooling can	ocity	kW	3.6	5.0	6.0
Cooling capa	acity	BTU/h	12,300	17,100	20,500
Heating con	1141		4.0	5.6	7.0
Heating capa	acity	BTU/h	13,600	19,100	23,900
Sound press (Cooling / Hea		dB(A)	43 / 44	45 / 48	46 / 49
	Sound power level (Cooling / Heating)		62 / 64	64 / 68	65 / 69
Unit dimensions (H×W×D)		mm	695×875×320	695×875×320	695×875×320
Net weight		kg	43	43	44

Operation condition temperature range

• Cooling mode : -15°C~46°C DB • Heating mode : -20°C~24°C DB

Europo	Model Name		U-71PZH2E5	U-100PZH2E5	U-125PZH2E5	U-140PZH2E5
Europe	Power so	urce		220 - 230 - 2	40 V∼ 50 Hz	
Cooling capa	ocity	kW	7.1	10.0	12.5	14.0
Cooling capa	acity	BTU/h	24,200	34,100	42,700	47,800
		kW	8.0	11.2	14.0	16.0
Heating capa	аспу	BTU/h	27,300	38,200	47,800	54,600
Sound press (Cooling / Hea		dB(A)	48 / 50	52 / 52	53 / 53	54 / 54
Sound powe (Cooling / Hea		dB(A)	65 / 67	69 / 69	70 / 70	71 / 71
Unit dimensions (H×W×D)		mm	996×940×340	1,416×940×340	1,416×940×340	1,416×940×340
Net weight kg		kg	68	99	99	99

Europo	Model Na	me	U-71PZH2E8	U-100PZH2E8	U-125PZH2E8	U-140PZH2E8	U-200PZH2E8	U-250PZH2E8
Europe	Power so	urce			380 - 400 - 415	5 V 3N∼ 50 Hz		
Cooling con	ooity	kW	7.1	10.0	12.5	14.0	19.5 / 20.0	23.2 / 25.0
Cooling cap	acity	BTU/h	24,200	34,100	42,700	47,800	66,500 / 68,200	79,200 / 85,300
Heating con	ooitu	kW	8.0	11.2	14.0	16.0	22.4	28.0
Heating capa	acity	BTU/h	27,300	38,200	47,800	54,600	76,400	95,500
Sound pressure level (Cooling / Heating)		dB(A)	48 / 50	52 / 52	53 / 53	54 / 54	59 / 61	59 / 63
Sound powe (Cooling / He		dB(A)	65 / 67	69 / 69	70 / 70	71 / 71	77 / 79	78 / 82
Unit dimens	ions	mm	996×940×340	1,416×940×340	1,416×940×340	1,416×940×340	1,500×980×370	1,500×980×370
Net weight		kg	68	99	99	99	117	128

Operation condition temperature range

• Cooling mode : -15°C~46°C DB (Type 71, 200, 250)

: -15°C (-20°C)\* ~46°C DB (Type 100, 125, 140)

\* It is possible to operate at -20°C only in the computer rooms with the piping length of 30 m or less.

• Heating mode : -20°C~24°C DB

Rated conditions

Cooling : Indoor intake air temp. 27°C DB / 19°C WB. Outdoor intake air temp. 35°C DB. Heating : Indoor intake air temp. 20°C DB. Outdoor intake air temp. 7°C DB / 6°C WB.

	Model Name		U-36PZ3E5	U-50PZ3E5	U-60PZ3E5	U-71PZ3E5			
Europe	Power so	urce		220 - 230 - 240 V~ 50 Hz					
01:	!4	kW	3.6	5.0	6.0	7.1			
Cooling cap	acity	BTU/h	12,300	17,100	20,500	24,200			
Heating con	noite.	kW	3.6	5.0	6.0	7.1			
Heating capa	acity	BTU/h	12,300	17,100	20,500	24,200			
	Sound pressure level (Cooling / Heating)		46 / 47	46 / 46	47 / 48	48 / 49			
Sound powe (Cooling / He		dB(A)	64 / 66	64 / 64	64 / 65	66 / 68			
Unit dimensions (H×W×D)		mm	619×824×299	619×824×299	695×875×320	695×875×320			
Net weight		kg	32	35	42	50			

Operation condition temperature range

• Cooling mode : -10°C~43°C DB • Heating mode : -15°C~24°C DB

F	Model Name		U-60PZ2E5	U-71PZ2E5	U-100PZ2E5	U-125PZ2E5	U-140PZ2E5		
Europe	Power source		220 - 230 - 240 V∼ 50 Hz						
0		kW	6.0	7.1	10.0	12.5	14.0		
Cooling cap	Cooling capacity		20,500	24,200	34,100	42,700	47,800		
Heating capacity		kW	6.0	7.1	10.0	12.5	14.0		
		BTU/h	20,500	24,200	34,100	42,700	47,800		
Sound pressure level (Cooling / Heating)		dB(A)	46 / 48	49 / 49	52 / 52	55 / 55	56 / 56		
Sound powe (Cooling / He		dB(A)	65 / 68	69 / 69	70 / 70	73 / 73	74 / 74		
Unit dimensions (H×W×D)		mm	695×875×320	695×875×320	996×980×370	996×980×370	996×980×370		
Net weight		kg	44	44	90	94	94		

Operation condition temperature range
• Cooling mode : -10°C~43°C DB
• Heating mode : -15°C~24°C DB

Eurono	Model Name		U-100PZ2E8	U-125PZ2E8	U-140PZ2E8		
Europe	Power source		380 - 400 - 415 V 3N∼ 50 Hz				
Cooling consoits		kW	10.0	12.5	14.0		
Cooming capa	Cooling capacity		34,100	42,700	47,800		
Heating consity		kW	10.0	12.5	14.0		
neating capa	Heating capacity		34,100	42,700	47,800		
Sound pressure level (Cooling / Heating)		dB(A)	52 / 52	55 / 55	56 / 56		
Sound power level (Cooling / Heating)		dB(A)	70 / 70	73 / 73	74 / 74		
Unit dimensions (H×W×D)		mm	996×980×370	996×980×370	996×980×370		
Net weight		kg	90	94	94		

Operation condition temperature range

• Cooling mode : -10°C~43°C DB • Heating mode : -15°C~24°C DB

Rated conditions

Cooling : Indoor intake air temp. 27°C DB / 19°C WB. Outdoor intake air temp. 35°C DB. Heating: Indoor intake air temp. 20°C DB. Outdoor intake air temp. 7°C DB / 6°C WB.

## **Specifications**

### **Outdoor unit**

### Single Split Outdoor Unit (R32)

	Model Name		U-71PZH2R5	U-100PZH2R5	U-125PZH2R5	U-140PZH2R5			
Oceania	Power source		230 - 240 V~ 50 Hz						
0 - 11		kW	7.1	10.0	12.5	14.0			
Cooling cap	Cooling capacity		24,200	34,100	42,700	47,800			
Heating capacity		kW	8.0	11.2	14.0	16.0			
		BTU/h	27,300	38,200	47,800	54,600			
Sound pressure level (Cooling / Heating)		dB(A)	48 / 50	52 / 52	53 / 53	54 / 54			
Sound power level (Cooling / Heating)		dB(A)	64 / 66	68 / 68	69 / 69	70 / 70			
Unit dimensions (H×W×D)		mm	996×940×340	1,416×940×340	1,416×940×340	1,416×940×340			
Net weight kg		kg	68	99	99	99			

Oceania	Model Name		U-100PZH2R8	U-125PZH2R8	U-140PZH2R8		
Oceania	Power source		400 - 415 V 3N∼ 50 Hz				
Cooling capacity		kW	10.0	12.5	14.0		
		BTU/h	34,100	42,700	47,800		
Heating conseits		kW	11.2	14.0	16.0		
neating capa	Heating capacity		38,200	47,800	54,600		
Sound pressure level (Cooling / Heating)		dB(A)	52 / 52	53 / 53	54 / 54		
Sound power level (Cooling / Heating)		dB(A)	68 / 68	69 / 69	70 / 70		
Unit dimensions (H×W×D)		mm	1,416×940×340	1,416×940×340	1,416×940×340		
Net weight		kg	99	99	99		

Operation condition temperature range
• Cooling mode : -15°C~46°C DB • Heating mode : -20°C~24°C DB

#### Rated conditions

Cooling : Indoor intake air temp. 27°C DB / 19°C WB. Outdoor intake air temp. 35°C DB. Heating: Indoor intake air temp. 20°C DB. Outdoor intake air temp. 7°C DB / 6°C WB.

Occania	Model Name		U-60PZ2R5	U-71PZ2R5	U-100PZ2R5	U-125PZ2R5	U-140PZ2R5		
Oceania	Power source		230 - 240 V∼ 50 Hz						
Cooling capacity		kW	6.0	7.1	10.0	12.5	14.0		
		BTU/h	20,500	24,200	34,100	42,700	47,800		
Heating capacity		kW	6.0	7.1	10.0	12.5	14.0		
		BTU/h	20,500	24,200	34,100	42,700	47,800		
Sound pressure level (Cooling / Heating)		dB(A)	46 / 48	49 / 49	52 / 52	55 / 55	56 / 56		
Sound powe (Cooling / He		dB(A)	65 / 66	67 / 67	68 / 67	70 / 70	71 / 71		
Unit dimensions (H×W×D)		mm	695×875×320	695×875×320	996×980×370	996×980×370	996×980×370		
Net weight		kg	44	44	90	94	94		

Operation condition temperature range
• Cooling mode : -10°C~43°C DB • Heating mode : -15°C~24°C DB

Oceania	Model Name		U-100PZ2R8	U-125PZ2R8	U-140PZ2R8		
Oceania	Power source		400 - 415 V 3N∼ 50 Hz				
Cooling capacity		kW	10.0	12.5	14.0		
		BTU/h	34,100	42,700	47,800		
Heeting consity		kW	10.0	12.5	14.0		
neating capa	Heating capacity		34,100	42,700	47,800		
	Sound pressure level (Cooling / Heating)		52 / 52	55 / 55	56 / 56		
Sound power level (Cooling / Heating)		dB(A)	68 / 67	70 / 70	71 / 71		
Unit dimensions (H×W×D)		mm	996×980×370	996×980×370	996×980×370		
Net weight		kg	90	94	94		

Operation condition temperature range
• Cooling mode : -10°C~43°C DB
• Heating mode : -15°C~24°C DB

Rated conditions Cooling : Indoor intake air temp. 27°C DB / 19°C WB. Outdoor intake air temp. 35°C DB. Heating : Indoor intake air temp. 20°C DB. Outdoor intake air temp. 7°C DB / 6°C WB.